



Addressable Alarm Bell

Model No.: AW-D109


Work Voltage: 18-28VDC @Loop

Standby Current: $\leq 3\text{mA}$ @Loop 24VDC

Alarm Current: $\leq 50\text{mA}$ @Loop 24VDC

Alarm SPL: $\geq 98\text{ dB}$ @1m

Work Temperature: $-10^{\circ}\text{C} \sim 50^{\circ}\text{C}$



ASENWARE LTD

ADDRESS: 6 PROSPECT WAY, ROYAL OAK INDUSTRIAL ESTATE DAVENTRY, NORTHAMPTONSHIRE, ENGLAND, NN118PL

WEBSITE: www.asenware.com EMAIL: info@asenware.com